

IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx CML 21.0048X Page 1 of 3 Certificate history:

R C Marshall

Status: Current Issue No: 0

Date of Issue: 2021-07-06

Applicant: Trolex Limited

Newby Road Hazel Grove Stockport Cheshire SK7 5DY

United Kingdom

Equipment: TX6648.35(xx...) 3.5 Ah UPS Power Supply and TX6649.35(xx...) 25 Ah UPS Power Supply

Optional accessory:

Type of Protection: Powder Filled "q", Increased Safety "eb", Intrinsic Safety "ia" / "[ia]"

Marking: Ex eb q [ia Ma] I Mb *

Ex ia I Ma **

Ta = -20°C to +55°C

*applies when the equipment is operating on mains power

**applies when the equipment is operating on battery back-up

Approved for issue on behalf of the IECEx

Certification Body:

Position: Operations Manager

Signature:

(for printed version)

Date: 2021-07-06

- 1. This certificate and schedule may only be reproduced in full.
- 2. This certificate is not transferable and remains the property of the issuing body.
- The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Eurofins E&E CML Limited Unit 1, Newport Business Park New Port Road Ellesmere Port, CH65 4LZ United Kingdom







IECEx Certificate of Conformity

Certificate No.: IECEx CML 21.0048X Page 2 of 3

Date of issue: 2021-07-06 Issue No: 0

Manufacturer: Trolex Limited

Newby Road Hazel Grove Stockport Cheshire SK7 5DY United Kingdom

Additional manufacturing locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements

Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition:6.0

5:2015 Explosive atmospheres –Part 5: Equipment protection by powder filling "q"

IEC 60079-5:2015 Edition:4.0

IEC 60079-7:2017 Edition:5.1

7 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

GB/CML/ExTR21.0089/00

Quality Assessment Report:

GB/SIR/QAR07.0017/10



IECEx Certificate of Conformity

Certificate No.: IECEx CML 21.0048X Page 3 of 3

Date of issue: 2021-07-06 Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The TX6648.35(.x...) and TX6649.35(.x...) Un-Interruptible Power Supply (UPS) incorporates a modified TX6641 Intrinsically safe power supply chassis housed inside a metal enclosure which is powder filled and sealed. It also incorporates a separate battery compartment, attached to the main enclosure which is not powder filled. A battery timer switch circuit board is located in the powder filled part of the enclosure. The battery timer switch circuit detects if the battery is being used to supply power and can switch off the power after a predetermined length of time.

Refer to Annex for full description and conditions of manufacture.

SPECIFIC CONDITIONS OF USE: YES as shown below:

Refer to Annex for specific conditions of use.

Annex:

IECEx CML 21.0048X Certificate Annex_1.pdf





Annexe to: IECEx CML 21.0048X Issue 0

Applicant: Trolex Limited

Apparatus: TX6648.35(.x...) 3.5Ah UPS Power Supply

TX6649.35(.x...) 25Ah UPS Power Supply

Description

The TX6648.35(.x...) and TX6649.35(.x...) Un-Interruptible Power Supply (UPS) incorporates a modified TX6641 Intrinsically safe power supply chassis housed inside a metal enclosure which is powder filled and sealed. It also incorporates a separate battery compartment, attached to the main enclosure which is not powder filled. A battery timer switch circuit board is located in the powder filled part of the enclosure. The battery timer switch circuit detects if the battery is being used to supply power and can switch off the power after a pre-determined length of time.

Only the 0.5A and 1.0A versions of the TX6641 Chassis are used for the UPS. The TX6648 uses two 3.5 Ah batteries and the TX6649 uses two 25 Ah batteries. These provide power to equipment located in the hazardous area if the mains power supply fails or is turned off for safety reasons.

When mains powered, this equipment is deemed to be Category M2(M1) EPL Mb(Ma) equipment. When battery powered, this equipment is deemed to be Category M1 EPL Ma Equipment

The Electrical output parameters are as follows:

Current output options - 0.5A or 1.0 A

Voltage output options - 7.5 V or 12 V

Input Supply options Um - 230 rms, 110 Vrms, 55 Vrms, 42 Vrms¹ or 24 Vrms

Note 1: Only available for TX6648 model

I.S. Output Terminals +V and 0 V

| 7.5 PSU (Uo = 8.5 V o/p crowbar) | Short Circuit current, lo in A | Max output Power, Po in W | Lo/Ro Ratio in μΗ/Ω | Capacitance, Co in µF |
|--|-----------------------------------|------------------------------|------------------------|--------------------------|
| 0.5 A | 0.873 | 5.28 | 72.69 | 646 |
| 1.0 A | 1.76 | 10.63 | 36.17 | 560 |

| 12.0 V PSU (Uo = 13.0 V o/p crowbar) | Short Circuit current, lo in A | Max output Power, Po in W | Lo/Ro Ratio in μΗ/Ω | Capacitance, Co in µF |
|--|-----------------------------------|------------------------------|---------------------|--------------------------|
| 0.5 A | 0.873 | 6.33 | 72.6 | 32.0 |
| 1.0 A | 1.76 | 12.73 | 36.17 | 30.29 |

1 of 3

Output terminal C1 (V_sig) and C2 (0V)

Unit 1, Newport Business Park New Port Road Ellesmere Port CH65 4LZ

T +44 (0) 151 559 1160 E info@cmlex.com

L IIII COIIII OX.COIII



 $Ui = 16.5 V Co = 10 \mu F$

 $Uo = 13.65 V \qquad Lo = 700 \text{ mH}$

lo = 25 mA lo/Ro = 5470 $\mu H/ohm$

Po = 85.2 mW

Ci = 12 nF

Li = 0

Output Terminals C3 (I_sig) and C2 (0V)

Ui = 16.5 V Ci = 12 nF

 $Pi = 0.3 W \qquad Li = 0$

Uo = 13.65 V $Co = 10 \mu F$

Io = 213.6 mA, Transient Lo = 9.4 mH

Io = 105.4 mA, continuous Lo/Ro = $312 \mu\text{H/ohm}$

Po = 1.25 W

Relay contact terminals P1 (common), P2 (normally closed) and P3 (normally open)

Ui = 90 V

Ii = 0.25 A

Pi = 3.0 W

Switch terminals T1 and T2

Connect to a volt free switch:

Ui = 0 V

Ii = 0 A

Pi = 0 W



Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. The Mains transformer shall be subjected to routine tests and be able to withstand a test voltage of at least 2500 Vrms applied between primary and secondary windings and at least 1000 Vrms applied between all windings and the core or screen.
- ii. The routine Electric strength test of the filling material shall be carried out prior to the filling process.

Specific Conditions of Use

The following conditions relate to safe installation and/or use of the equipment.

- i. All cable entries shall be made using suitably certified Ex e cable glands.
- ii. The use of conduit is not permitted